



PRE-RELEASE VERSION (FDIS)

**Low-voltage switchgear and controlgear –
Part 8: Control units for built-in thermal protection (PTC) for rotating electrical
machines**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.20

Warning! Make sure that you obtained this publication from an authorized distributor.



This is a preview - click here to buy the full publication

121A/424/FDIS

FINAL DRAFT INTERNATIONAL STANDARD (FDIS)

PROJECT NUMBER:

IEC 60947-8 ED2

DATE OF CIRCULATION:

2021-05-28

CLOSING DATE FOR VOTING:

2021-07-09

SUPERSEDES DOCUMENTS:

121A/370/CDV, 121A/412A/RVC

IEC SC 121A : LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR

SECRETARIAT:

France

SECRETARY:

Mr Michaël LAHEURTE

OF INTEREST TO THE FOLLOWING COMMITTEES:

TC 2

HORIZONTAL STANDARD:

FUNCTIONS CONCERNED:

EMC

ENVIRONMENT

QUALITY ASSURANCE

SAFETY

SUBMITTED FOR CENELEC PARALLEL VOTING

NOT SUBMITTED FOR CENELEC PARALLEL VOTING

Attention IEC-CENELEC parallel voting

The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Final Draft International Standard (FDIS) is submitted for parallel voting.

The CENELEC members are invited to vote through the CENELEC online voting system.

This document is a draft distributed for approval. It may not be referred to as an International Standard until published as such.

In addition to their evaluation as being acceptable for industrial, technological, commercial and user purposes, Final Draft International Standards may on occasion have to be considered in the light of their potential to become standards to which reference may be made in national regulations.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

TITLE:

Low-voltage switchgear and controlgear - Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines

PROPOSED STABILITY DATE: 2024

NOTE FROM TC/SC OFFICERS:

SC121A Officers support circulation of FDIS for project IEC 60947-8 ED2.

Copyright © 2021 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

CONTENTS

FOREWORD	5
INTRODUCTION	7
1 Scope	8
2 Normative references	8
3 Terms and definitions, symbols and abbreviated terms	9
3.1 Terms and definitions	9
3.2 Symbols and abbreviated terms	11
4 Void	11
5 Characteristics of control units for built-in thermal protection (PTC)	11
5.1 Summary of characteristics	11
5.2 Type of equipment	11
5.2.1 Operating temperatures of protection systems	11
5.2.2 Rated PTC thermistor operating temperature	11
5.2.3 Rated system operating temperature	12
5.2.4 Maximum permissible rated operating temperature for the system	12
5.2.5 Control unit with reset temperature	12
5.2.6 Control unit with sensor short-circuit detection	12
5.2.7 Control unit with sensor wire break detection	12
5.3 Rated electrical values of the switching device of the control unit	13
5.3.1 Rated electrical values of switching devices	13
5.3.2 Rated voltages of a control unit	13
5.3.3 Rated currents of a control unit	13
5.3.4 Rated making and breaking capacities of a control unit	13
5.4 Rated electrical values of characteristic variation related to PTC thermistors	13
5.4.1 General	13
5.4.2 Electrical data/ratings and characteristics related to the PTC thermistor	13
5.4.3 Rated voltage of the PTC thermistor circuit of the control unit	14
5.5 Control supply circuit	14
5.6 Auxiliary circuits	14
6 Product information	14
6.1 Nature of information	14
6.2 Marking	15
6.3 Instructions for installation, operation and maintenance, decommissioning and dismantling	15
6.4 Environmental information	15
7 Normal service, mounting and transport conditions	15
8 Constructional and performance requirements	16
8.1 Constructional requirements	16
8.1.1 General	16
8.1.2 Materials	17
8.1.3 Current-carrying parts and their connections	17
8.1.4 Clearances and creepage distances	17
8.1.5 Vacant	17
8.1.6 Vacant	17
8.1.7 Vacant	17

8.1.8	Terminals	17
8.1.9	Vacant	18
8.1.10	Provisions for protective earthing	18
8.1.11	Dedicated enclosures for equipment	18
8.1.12	Degrees of protection of enclosed equipment	18
8.1.13	Conduit pull-out, torque and bending with metallic conduits	18
8.1.14	Limited energy source	18
8.1.15	Stored charge energy circuit	20
8.1.16	Fault and abnormal conditions	20
8.1.17	Short-circuit and overload protection of ports	21
8.2	Performance requirements	21
8.2.1	Operating conditions	21
8.2.2	Abnormal conditions of service	22
8.2.3	Dielectric properties	22
8.2.4	Temperature rise	22
8.2.5	Conditional short-circuit current	22
8.2.6	Making and breaking capacities for control and auxiliary circuits	22
8.2.7	Additional requirements and tests for equipment with protective separation	22
8.2.8	Operating temperature variation	22
8.2.9	Damp heat	22
8.2.10	Shock and vibration	22
8.2.11	Requirements for short-circuit detection within the PTC thermistor circuit	23
8.2.12	Requirements for wire break detection within the PTC thermistor circuit	23
8.3	Electromagnetic compatibility (EMC)	23
8.3.1	General	23
8.3.2	Immunity	23
8.3.3	Emission	24
9	Tests	24
9.1	Kinds of tests	24
9.1.1	General	24
9.1.2	Type tests	24
9.1.3	Routine tests	24
9.1.4	Sampling tests	25
9.1.5	Special tests	25
9.2	Compliance with constructional requirements	25
9.2.1	General	25
9.2.2	Electrical performance of screwless-type clamping units	25
9.2.3	Ageing test for screwless-type clamping units	25
9.2.4	Limited energy source test	25
9.2.5	Breakdown of components	26
9.3	Compliance with performance requirements	27
9.3.1	Test sequences	27
9.3.2	General test conditions	28
9.3.3	Performance	28
9.3.4	Performance under conditional short-circuit current	32
9.4	EMC tests	32
9.4.1	General	32

9.4.2	Immunity.....	32
9.4.3	Emission.....	33
9.5	Routine and sampling tests	34
9.5.1	General	34
9.5.2	Operating tests on control units	34
9.5.3	Dielectric tests.....	34
9.5.4	Routine verification of switch on and switch off of Mark A control units	34
Annex A (normative)	PTC thermistors used in thermal protection systems	35
A.1	Characteristics of association of Mark A thermistors	35
A.2	Verification of interchangeability characteristics	35
A.2.1	Type tests on Mark A thermistors.....	35
A.2.2	Routine tests on Mark A thermistors	36
Annex B (normative)	Additional requirements and tests for equipment with protective separation.....	37
B.1	General.....	37
B.2	Definitions.....	37
B.3	Requirements	37
B.3.1	Test method for implementing protective impedance.....	37
B.3.2	Touch current measurement	38
Bibliography	40
Figure 1	– Measurement of wire break detection	31
Figure A.1	– Characteristic curve of a typical Mark A thermistor.....	36
Figure B.1	– Protection by means of protective impedance	38
Figure B.2	– Measuring instrument	39
Table 1	– Limits for limited energy sources without an over-current protective device	19
Table 2	– Limits for limited energy sources with an over-current protective device	19
Table 3	– Limits for limited energy source with current limiting impedance	20
Table 4	– Terminal disturbance voltage limits for conducted radio-frequency emission (for control supply input)	33
Table 5	– Radiated emission test limits	33

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60947-8 has been prepared by subcommittee 121A: Low voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage. It is an International Standard.

This second edition cancels and replaces the first edition published in 2003, Amendment 1:2006 and Amendment 2:2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) safety aspects related to:
 - general aspects;
 - limited energy circuits;
 - electronic circuits;
- b) alignment to IEC 60947-1:2020;

- c) wire break detection function;
- d) the term detector is replaced by thermistor;
- e) reference to IEC 60738-1-4.

The provisions of the general rules dealt with IEC 60947-1 are applicable to this part of IEC 60947 series where specifically called for. Clauses and subclauses, tables, figures and annexes of the general rules thus applicable are identified by reference to IEC 60947-1:2020.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
121A/XX/FDIS	121A/XX/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all the parts in the IEC 60947 series, under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Thermal protection systems which are based on the principle of monitoring the temperature of the protected parts constitute a simple and effective means of protecting rotating electrical machines, called also electric motors, against excessive temperature rises, including those caused by faults in the cooling system, or excessively high ambient temperature, whereas systems of protection based only on monitoring the current absorbed do not ensure this type of protection in every circumstances.

Since the operating temperature and response times of thermal protection systems are fixed in advance, they are not often adjusted in relation to the conditions of use of the machine and, hence, they are not be completely effective for all fault conditions, or improper use of the machine.

A thermal protection system in accordance with this document can consist of a characteristic change thermal detector which has an associated control unit to convert a point on the characteristic of the detector to a switching function. A very large number of thermal protection systems are in use and, in all cases, the machine manufacturer will fit the detectors in the machine. The machine manufacturer will either supply the control unit with the machine or specify particulars of the control unit to be used.

It is also customary for the control units to be considered as part of the control system and not necessarily supplied with the machine. For this reason, it is considered useful to have an interchangeable system, where the characteristics of association between the detector and the control unit are specified. This particular system is not considered superior in any way to other systems complying with the requirements of this document, but in some fields the practice is likely to be that this interchangeable system will be used, as indicated by the designation "Mark A".

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines

1 Scope

This part of IEC 60947 series specifies requirements for control units, which control a switching device in response to the PTC thermistors incorporated in rotating electrical machines and the industrial application.

It specifies requirements for that type of system comprising a positive temperature coefficient (PTC) thermistor having particular characteristics, and its associated control unit.

This document includes:

- the characteristics, construction, performance and tests of the control unit; and
- its association with a PTC thermistor designated “Mark A”.

This document does not cover:

- the incorporation of thermal protections into rotating machines and their maximum winding temperature. See IEC 60034-11;
- use of the product within explosive atmospheres (see IEC 60079 (all parts));
- software and firmware requirements;

NOTE 1 Guidance on embedded software is given in IEC TR 63201.

- cyber security aspects (see IEC TS 63208).

NOTE 2 It is not possible to specify all the requirements for the operating characteristics of a control unit, as they are dependent on some aspects of the PTC thermistors. Some aspects of the requirements of the thermal protector system can only be specified when account is taken of the characteristics of the rotating machine to be protected and the method of installation of the PTC thermistor within the machine.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

CISPR 11:2015, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 11:2015/AMD1:2016

CISPR 11:2015/AMD2:2019

IEC 60068-2-6:2007, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27:2008, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*

IEC 60417, *Graphical symbols for use on equipment* (available at <http://www.graphical-symbols.info/equipment>)

IEC 60445, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60730-1, *Automatic electrical controls – Part 1: General requirements*

IEC 60738-1:2006, *Thermistors – Directly heated positive temperature coefficient – Part 1: Generic specification*

IEC 60738-1:2006/AMD1:2009

IEC 60738-1-4:2008, *Thermistors – Directly heated positive step-function temperature coefficient – Part 1-4: Blank detail specification – Sensing application – Assessment level EZ*

IEC 60947-1:2020, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 60947-5-1:2016, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 61140:2016, *Protection against electric shock – Common aspects for installation and equipment*

ISO 2859-1:1999, *Sampling procedures for inspection by attributes – Part 1: Sampling schemes indexed by acceptance quality limit (AQL) for lot-by-lot inspection*

ISO 2859-1:1999/AMD1:2011